

Project: Project Name (eB #)

- Is emergency power available? Are the emergency lights on battery or generator? If using existing generator, is capacity sufficient?
- Are exit signs in the proper locations?
- Is selection of battery-pack and/or "Bodine" ballast appropriate?
- Was emergency lighting provided in utility rooms?
- Fuel source for emergency generator? If gas, is pressure sufficient?
- Transfer option for emergency generator? Closed transition specified?
- Were appropriate Standards followed?
- Do life safety, legally required, and optional standby power sources have proper code required separations?